



116 East 16th Street
New York, New York 10003-2112

Phone (212) 777-4445
Fax (212) 505-8419
E-mail: dllabs@aol.com

Accredited by National Voluntary Laboratory Accreditation Program - Lab Code 100252
Accepted by Canadian General Standards Board - No. 76005 - ISO/IEC 25 Approved

December 19, 1996

United Coatings
E. 19011 Cataldo
Green Acres, WA 99016

Attn: Mr. Shawn Carney

DL – 11349A

OBJECTIVE

To test a waterproofing material for conformance to the requirements for Water Repellency on Masonry, as outlined in Par. 3.5 of Federal Specification SS-W-110C.

PRODUCT TESTED

The waterproofing material was identified as Canyon Tone Clear.

TEST PROCEDURE

The sample was tested in accordance with procedures outlined in Federal Specification SS-W-110C, Par. 4.3.2. Two inch mortar cubes were used as the test substrate.

TEST RESULTS

The test results are as follows.

<u>Test</u>	<u>Requirement</u>	<u>Result</u>
Water Repellency on Masonry Water absorption, %	1.0 max.	
Canyon Tone Clear		0.3%

This report may contain test data obtained from test methods not covered by NVLAP accreditation. See reverse side for those test methods which are covered.

This report shall not be reproduced except in full without the prior written approval of the DL Labs, Inc. The information contained herein is not endorsed by NVLAP, CGSB or any agency of the U.S. or Canadian governments and no such endorsement may be claimed.



Attn: Mr. Shawn Carney
Re: DL - 11349A

CONCLUSION

The submitted sample of Canyon Tone Clear conforms to the requirement for Water Repellency on Masonry as outlined in Par. 3.5 of Federal Specification SS-W-110C.

DL Labs, Inc.

A handwritten signature in black ink, appearing to read 'Thomas J. Sliva', written in a cursive style.

Thomas J. Sliva
Assistant Technical
Director