



74 Kent Street
Brooklyn, New York 11222-1517

Phone (718) 383-5080
Fax (718) 383-7445
E-mail: dllabs@aol.com

Accredited by National Voluntary Laboratory Accreditation Program - Lab Code 100252
ISO / IEC 17025 and relevant requirements of ISO 9002

March 16, 2005

United Coatings
19011 Cataldo Avenue
Spokane Valley, WA 99016

Att: **Mr. Mike Sand**

DL-14450C
Via FAX (509) 928-1116

OBJECTIVE

To evaluate submitted test assemblies coated with a waterproofing material for crack bridging.

PRODUCT TESTED

The test assemblies were submitted by United Coatings and the waterproofing membrane identified as Elastuff 310.

TEST PROCEDURE

Testing was conducted in accordance with procedures outlined in Par. 5.7.4, Low-Temperature Flexibility and Crack Bridging of ASTM C 836.

CONCLUSION

The waterproofing material did not exhibit any cracking or loss of adhesion after completion of 10 cycles of movement.

DL Labs, Inc.

A handwritten signature in black ink, appearing to read 'Thomas J. Sliva'.

Thomas J. Sliva
Vice President/
Technical Director

mb

cc: M. Lazaro, Jr.

This report may contain test data obtained from test methods not covered by NVLAP accreditation. See reverse side for those test methods which are covered.

This report shall not be reproduced except in full without the prior written approval of the DL Labs, Inc. The information contained herein is not endorsed by NVLAP or any other agency of the U.S. government and no such endorsement may be claimed.